

## Altmar Parish Williamstown Central Schools

639 County Route 22, P.O. Box 97, Parish, NY 13131

Junior Senior High School  
Lab ELAP id# 10478

Last updated: 06-16-21  
Method of Analysis: EPA Method 200.8

### Results of Lead Testing – Junior Senior High School

Lab ID	School Sample ID	Collection	Sample Location	Outlet Description	Initial/Post Remediation	Result <15 PPB	Result >15 PPB	Lab Results Receipt	Action Taken
11246	HT01-1	04/28/21 4:45	BR	Cold Water Outlet	Initial		378	06/09/21	Replaced Faucet Posted Signage
		06/10/21 6:08			Post Remediation	1		06/16/21	
11246	HT01-2	04/28/21 4:45	BR	Cold Water Outlet	Initial	1.5		06/09/21	N/A
11246	HGX02	04/28/21 5:18	Women's BR by FCS	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT02-1	04/28/21 4:47	BR	Cold Water Outlet	Initial	1.3		06/09/21	N/A
11246	HT02-2	04/28/21 4:47	BR	Cold Water Outlet	Initial	7.1		06/09/21	N/A
11246	HL03-1	04/29/21 5:49	Aud/Gym Lobby	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HL03-2	04/29/21 5:49	Aud/Gym Lobby	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HL03-3	04/29/21 5:50	Aud Hall BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HL03-4	04/29/21 5:52	Aud Hall BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT05	04/28/21 4:51	Spec. Ed. Ofc. BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HGX05-1	04/28/21 5:30	BR by rm 121	Cold Water Outlet	Initial	1		06/09/21	N/A

**Altmar Parish Williamstown Central Schools**  
**639 County Route 22, P.O. Box 97, Parish, NY 13131**

Junior Senior High School  
 Lab ELAP id# 10478

Last updated: 06-16-21  
 Method of Analysis: EPA Method 200.8

**Results of Lead Testing – Junior Senior High School**

Lab ID	School Sample ID	Collection	Sample Location	Outlet Description	Initial/Post Remediation	Result <15 PPB	Result >15 PPB	Lab Results Receipt	Action Taken
11246	HCX05-2	04/28/21 5:32	BR by rm 122	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HCX06-1	04/28/21 5:33	Corridor	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HCX06-2	04/28/21 5:33	Corridor	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HCX07	04/28/21 5:36	Corridor	Cold Water Outlet	Initial	1.1		06/09/21	N/A
11246	HCC1	04/28/21 4:46	Corridor	Cold Water Outlet	Initial	2.4		06/09/21	N/A
11246	HEC1	04/28/21 4:34	Corridor	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HUC1	04/29/21 6:14	Upstairs Corridor	Cold Water Outlet	Initial	2.2		06/09/21	N/A
11246	HC100B	04/28/21 5:00	Nurse	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HB101	04/28/21 5:26	122	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HD101	04/29/21 5:27	Chorus	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT10-1	04/28/21 5:20	BR	Cold Water Outlet	Initial	4.2		06/09/21	N/A

## Altmar Parish Williamstown Central Schools

639 County Route 22, P.O. Box 97, Parish, NY 13131

Junior Senior High School  
Lab ELAP id# 10478

Last updated: 06-16-21  
Method of Analysis: EPA Method 200.8

### Results of Lead Testing – Junior Senior High School

Lab ID	School Sample ID	Collection	Sample Location	Outlet Description	Initial/Post Remediation	Result <15 PPB	Result >15 PPB	Lab Results Receipt	Action Taken
11246	HT10-2	04/28/21 5:21	BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HD103	04/29/21 5:25	Band	Cold Water Outlet	Initial	6.5		06/09/21	N/A
11246	HE103A	04/29/21 6:00	Ice Room	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HE103B	04/29/21 6:30	Kitchen	Ice Machine	Initial	1		06/09/21	N/A
11246	HE105-1	04/29/21 6:11	P.E. Ofc BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HE107-1	04/29/21 6:08	Boys LR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HE107-2	04/29/21 6:08	Boys LR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HE107-3	04/29/21 6:10	Boys LR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC108	04/28/21 5:26	Men's BR by ISS	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HF109	04/28/21 4:42	DO - Supt. BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC109-1	04/28/21 5:11	108	Cold Water Outlet	Initial	2		06/09/21	N/A
11246	HE109-1	04/29/21 6:02	Girls LR	Cold Water Outlet	Initial	1		06/09/21	N/A

## Altmar Parish Williamstown Central Schools

639 County Route 22, P.O. Box 97, Parish, NY 13131

Junior Senior High School  
Lab ELAP id# 10478

Last updated: 06-16-21  
Method of Analysis: EPA Method 200.8

### Results of Lead Testing – Junior Senior High School

Lab ID	School Sample ID	Collection	Sample Location	Outlet Description	Initial/Post Remediation	Result <15 PPB	Result >15 PPB	Lab Results Receipt	Action Taken
11246	HC109-2	04/28/21 5:12	108	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HE109-2	04/29/21 6:03	Girls LR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC109-3	04/28/21 5:12	108	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HE109-3	04/29/21 6:04	Girls LR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC109-4	04/28/21 5:13	108	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HA110-1	04/29/21 5:32	Library	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC110-1	04/28/21 4:59	Nurse	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HE110-1	04/29/21 5:58	P.E. Ofc BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HA110-2	04/29/21 5:34	Library	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC110-2	04/28/21 5:00	Nurse	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HA110-3	04/29/21 5:34	Library	Cold Water Outlet	Initial	1		06/09/21	N/A

**Altmar Parish Williamstown Central Schools**  
**639 County Route 22, P.O. Box 97, Parish, NY 13131**

Junior Senior High School  
 Lab ELAP id# 10478

Last updated: 06-16-21  
 Method of Analysis: EPA Method 200.8

**Results of Lead Testing – Junior Senior High School**

Lab ID	School Sample ID	Collection	Sample Location	Outlet Description	Initial/Post Remediation	Result <15 PPB	Result >15 PPB	Lab Results Receipt	Action Taken
11246	HA110C	04/29/21 5:33	Lib WR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT11-1	04/28/21 5:22	BR	Cold Water Outlet	Initial	1.9		06/09/21	N/A
11246	HC111-1	04/28/21 4:56	SBHC	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HF111-1	04/28/21 4:39	DO Conf Room	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC111-2	04/28/21 4:57	SBHC	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HF111-2	04/28/21 4:40	DO Conf Room	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC111B	04/28/21 4:57	SBHC	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC112	04/28/21 4:50	102 Fac Rm	Cold Water Outlet	Initial	1.1		06/09/21	N/A
11246	HE112	04/29/21 5:47	BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HF112	04/28/21 4:38	DO Mail Room	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT11-2	04/28/21 5:22	BR	Cold Water Outlet	Initial	1		06/09/21	N/A

## Altmar Parish Williamstown Central Schools

639 County Route 22, P.O. Box 97, Parish, NY 13131

Junior Senior High School  
Lab ELAP id# 10478

Last updated: 06-16-21  
Method of Analysis: EPA Method 200.8

### Results of Lead Testing – Junior Senior High School

Lab ID	School Sample ID	Collection	Sample Location	Outlet Description	Initial/Post Remediation	Result <15 PPB	Result >15 PPB	Lab Results Receipt	Action Taken
11246	HF112-1	04/29/21 6:30	DO (by Mail Room) BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC114	04/28/21 4:53	101 - MO Kitchen	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HC114-1	04/28/21 4:54	Main Ofc BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HF115-1	04/28/21 4:19	Kitchen	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HF115-2	04/28/21 4:19	Kitchen	Cold Water Outlet	Initial	2.1		06/09/21	N/A
11246	HF115-3	04/28/21 4:20	Kitchen	Cold Water Outlet	Initial	1.1		06/09/21	N/A
11246	HF115-4	04/28/21 4:21	Kitchen	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HF115-5	04/28/21 4:21	Kitchen	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HF115-6	04/28/21 4:25	Kitchen	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT12	04/28/21 5:27	121 - Spec. Ed. BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HGX13	04/29/21 6:28	DO (by Clerk) BR	Cold Water Outlet	Initial	1		06/09/21	N/A

## Altmar Parish Williamstown Central Schools

639 County Route 22, P.O. Box 97, Parish, NY 13131

Junior Senior High School  
Lab ELAP id# 10478

Last updated: 06-16-21  
Method of Analysis: EPA Method 200.8

### Results of Lead Testing – Junior Senior High School

Lab ID	School Sample ID	Collection	Sample Location	Outlet Description	Initial/Post Remediation	Result <15 PPB	Result >15 PPB	Lab Results Receipt	Action Taken
11246	HT17-1	04/29/21 5:21	BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT17-2	04/29/21 5:22	BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT18-1	04/29/21 5:23	BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT18-2	04/29/21 5:23	BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT19	04/29/21 5:42	Outside BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HEC2	04/28/21 4:34	Corridor	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT20	04/29/21 5:44	Outside BR	Cold Water Outlet	Initial	2.7		06/09/21	N/A
11246	HT29	04/28/21 4:30	Men's BR by dock	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT30	04/28/21 4:25	Women's BR by dock	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HEC4	04/28/21 4:32	Near Dock BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT41-1	04/29/21 6:15	BR	Cold Water Outlet	Initial	1		06/09/21	N/A

# Altmar Parish Williamstown Central Schools

639 County Route 22, P.O. Box 97, Parish, NY 13131

Junior Senior High School  
Lab ELAP id# 10478

Last updated: 06-16-21  
Method of Analysis: EPA Method 200.8

## Results of Lead Testing – Junior Senior High School

Lab ID	School Sample ID	Collection	Sample Location	Outlet Description	Initial/Post Remediation	Result <15 PPB	Result >15 PPB	Lab Results Receipt	Action Taken
11246	HT41-2	04/29/21 6:16	BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT42-1	04/29/21 6:16	BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HT42-2	04/29/21 6:18	BR	Cold Water Outlet	Initial	1		06/09/21	N/A
11246	HEC5	04/28/21 4:33	Near Dock BR	Cold Water Outlet	Initial	1		06/09/21	N/A